

Miami River Project Unscheduled Maintenance

Basin	Line Segment	Date	Address	Corrective
Customer Comlaint	Problem Found		Remarks	
1 B Sewer Backup	14 Main Stoppage	12 11/14/02	661 NW 2 ST BLOCKAGE DUE TO DEBRIS; REFER TO RADIO; TOWELS	Cleared Main
1 B Sewer Backup	16 Main Stoppage	33 12/18/02	658 NW 1 ST F-14; BLOCKAGE DUE TO GREASE;	Cleared Main & Service
1 A Bad Odor Complaint	20 Other, NOT a Sewer Problem	19 11/27/02	118 NW S. RIVER DR F-14; BROKEN M/H BASE; OVER INTERCEPTOR (72") V. BECKFORD MADE REPAIR	Referred to Repair Crew
1 B Br Sewer Line	40 Br Lateral	41 12/13/02	535 SW 1 ST F-14; 6" LATERAL BROKEN BY PRIVATE CONTRACTOR; V. BECKFORD MADE REPAIR	Referred to Repair Crew

Basin	Line Segment	Date	Address	Corrective
Customer Complaint	Problem Found		Remarks	
1 B Sewer Backup	43 Main Stoppage	44 10/23/02	550 NW 1 ST BLOCKAGE DUE TO GREASE; NIGHT SHIFT;	Cleared Main & LATERAL
1 B Sewer Backup	96 Lateral Stoppage	94 12/20/02	731 SW 5 ST NIGHT SHIFT; BLOCKAGE DUE GREASE	Cleared Main & Service
1 B MH Overflow	100 Other, NOT a Sewer Problem	102 12/26/02	405 SW 5 ST F-14; MAIN OK; INSIDE PROBLEM	Other, NOT a Sewer Problem
1 B Br Sewer Line	119 Br Lateral	115 10/1/02	224 SW 6 ST F-14; BROKEN 4" LATERAL; V. BECKFORD CREW NOTIFIED	Referred to Repair Crew
1 B MH Overflow	124 Main Stoppage	139 12/4/02	4 AVE SW 7 ST F-14;	Cleared Main

Basin	Line Segment	Date	Address	Corrective
Customer Complaint	Problem Found		Remarks	
1 B Sewer Backup	137 Other, NOT a Sewer Problem	218 10/3/02	471 SW 8 ST F-14; NO 2ND C/O EXPOSED; MAIN LINE DOWN	Other, NOT a Sewer Problem
1 B Sewer Backup	137 Lateral Stoppage	218 10/10/02	471 SW 8 ST F-14; CUSTOMER BEING ADVISED TO EXPOSE 2ND C/O; CHARGE; CUST ACCT # A1619504200	Other, NOT a Sewer Problem
1 B Sewer Backup	186 Main Stoppage	184 12/19/02	620 S. MIAMI AVE BLOCKAGE DUE TO OTHER DEBRIS; PAPER TOWELS	Cleared Main & Service
1 B Sewer Backup	218 Main Stoppage	219 12/9/02	5 AVE SW 8 ST BLOCKAGE DUE GREASE;	Cleared Main
1 B Sewer Backup	235 Lateral Stoppage	240 11/19/02	937 SW 5 ST NIGHT SHIFT	Cleared Main & Service
1 B Sewer Backup	235 Other, NOT a Sewer Problem	240 12/12/02	500 SW 9 AVE G-14; INSIDE PROLEM;	Other, NOT a Sewer Problem

Basin	Line Segment	Date	Address	Corrective
Customer Complaint	Problem Found		Remarks	
1 B Br Sewer Line	261 37 Br Lateral	12/10/02	744 SW 1 ST MARKS ON GROUND	Referred to Repair Crew
1 B Br Sewer Line	261 37 Br Lateral	12/2/02	1 ST SW 7 AVE TWO 6" LATERAL BROKEN BY PANAMERICAN CONSTRUCTION; NIGHT SHIFT; A. LIMA MADE REPAIR	Referred to Repair Crew
1 D Sewer Backup	265 264 Main Stoppage	12/29/02	1881 NW 19 AVE ON-CALL; BLOCKAGE DUE TO GREASE	Cleared Main & Service
1 D Sewer Backup	268 269 Main Stoppage	12/25/02	721 NW 2 ST ON-CALL; PROBLEM AT LATERAL ; NEED TV; BLOCKAGE DUE TO GREASE	Cleared Main & Service
1 B Sewer Backup	275 290 Main Stoppage	12/30/02	955 NW 3 ST NIGHT; BLOCKAGE DUE TO GREASE	Cleared Main & Service
1 B MH Overflow	336 337 Main Stoppage	11/27/02	1044 NW 5 ST G-14; BLOCKAGE DUE GREASE;	Cleared Main

Basin	Line Segment	Date	Address	Corrective
Customer Complaint	Problem Found		Remarks	
1 B MH Overflow	337 330 Main Stoppage	10/17/02	NW 4-5 ST & NW 12 AVE G-14; BLOCKAGE DUE TO GREASE; NO CHARGE;	Cleared Main
1 B MH Overflow	345 344 Other, NOT a Sewer Problem	10/2/02	1151 NW 4 ST G-14; NO CHARGE;	OTHER
1 B MH Overflow	392 441 Br Gravity	10/31/02	NW 14 AVE & 2 ST G-14; NO CHARGE; ALSO CHECKED ON USM FORM (MAIN STOPPAGE); AS PER V. WALTERS	Cleared Main
1 A MH Overflow	829 830 Other, NOT a Sewer Problem	11/25/02	850 S. MIAMI AVE M/L DOWN' NO 2ND C/O; CUSTOMER NEEDS PLUMBER	Other, NOT a Sewer Problem
2 I MH Overflow	432 431 Main Stoppage	11/20/02	235 NW 35 ST F-12; LOTS OF SAND IN M/L	Cleared Main
2 H Other Sewer Problem	467 466 Other, NOT a Sewer Problem	10/21/02	268 NW 11 ST F-13; NO CHARGE; NO PROBLEM FOUND	Other, NOT a Sewer Problem

Basin	Line Segment	Date	Address	Corrective	
Customer Complaint	Problem Found		Remarks		
2 H	477	486	10/23/02	950 NW 3 AVE	Cleared Main
Sewer Backup	Main Stoppage			F-13; LOTS OF GREASE IN MAIN-VACTOR CLEANED MAINLINES; NO CHARGE; (S. PRICHARD W/ CITY OF MIAMI PUBLIC WORKS)	
20 A	30	4	10/2/02	1705 NW 7 ST	Other, NOT a Sewer Problem
Sewer Backup	Other, NOT a Sewer Problem			G-13; NIGHT SHIFT; M/L DOWN CUSTOMER FULL OF GREASE; POSSIBLE GREASE TRAPS & STORM DRAINS TIED IN TOGETHER; BACKUPS WHEN RAINING	
55 A	10	9	10/21/02	NW 18 AVE & NW 6 ST	Cleared Main
Other Sewer Problem	Main Stoppage			H-14; BLOCKAGE DUE TO GREASE; NO CHARGE	
71 A	35	36	10/19/02	851 NW 18 PL	Cleared Main & Service
MH Overflow	Lateral Stoppage			H-13; ON-CALL; SINGLE SERVICE;	
80 A	33	32	12/6/02	2750 NW S RIVER DR	Other, NOT a Sewer Problem
MH Overflow	Other, NOT a Sewer Problem			J-13; INSIDE PROBLEM; NOTIFIED RADIO ROOM	
81 A	30	29	12/31/02	3591 NW 20 ST	Referred to Repair Crew
Br Sewer Line	Br Force Main			ON-CALL; (SPILL); BROKEN 20" FM;	

Basin	Line Segment	Date	Address	Corrective	
Customer Complaint	Problem Found		Remarks		
102 A	4	3	10/28/02	3333 NW 21 ST	Cleared Main
MH Overflow	Main Stoppage			BLOCKAGE DUE TO GREASE; NIGHT SHIFT;	
117 A	119	118	12/11/02	1310 NW 35 AVE	Cleared Service
Sewer Backup	Lateral Stoppage			J-13; BLOCKAGE DUE TO GREASE	